



NOTES:

SECTION A-A

1. EQUIPMENT SHALL BE ADEQUATELY SUPPORTED.
2. WATER METER REMOTE REGISTER SHALL BE MOUNTED TO A FLOOR JOIST IN THE BASEMENT TO AVOID POSSIBLE WATER DAMAGE. FRONT OF TRANSMITTER SHALL FACE THE STREET AND BE MOUNTED AS CLOSE TO THE FRONT OF THE BASEMENT AS POSSIBLE.
3. WATER METER SHALL BE LOCATED AT LEAST 12" FROM WALL.
4. SCHEMATIC DRAWING FOR GENERAL INSTALLATION DIRECTIONS ONLY. FIELD CONDITIONS MAY VARY.
5. ALL EXISTING RESIDENTS ON THE HUDSON WATER SYSTEM SHALL BE REQUIRED TO REMOVE EXISTING METER AND INSTALL, AT MINIMUM, A FLOW METER WITH UPSTREAM AND DOWNSTREAM BALL VALVES.
6. ALL OTHER RESIDENTS SHALL BE REQUIRED TO INSTALL, AT MINIMUM, A FLOW METER WITH UPSTREAM AND DOWNSTREAM BALL VALVES.

**TOWN OF CLAVERACK
COLUMBIA COUNTY, NEW YORK
STANDARD WATER DISTRIBUTION DETAILS**

**TYPICAL WATER SERVICE
SCHEMATIC WITHIN BASEMENT**

FIGURE 9

MAY 2006

NO SCALE